

## Water Quality Parameter Monitoring Form

## **Lead & Copper Rule Corrosion Control**

Day	рН	Alk	Phos	Other	Y/N	< <hr/> Have ENTDY DOINT
1	8,0					minimums ENTRY POINT
2	8,1					been met for this day? PWS ID: 41 9 0 5 3 1
3	8,0					
4	8.1					System Name: Tewelle SD. 8
5	8.1					Entry Point: School
6	8,1					Sample Period: 12/2022
7	8,1					Month/Year
8	8,0					Number of excursions* during this month:
9	8.0					(Count the number of days when any WQP was
10	6,1	176				less than the minimum required)
11	811	, f.	>			900 d 5
12	8,0					Total excursions during the previous 5 months:
13	8,1					(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)
14	810					i one and blothbation executations are cumulative ;
15	8,1					For OHA use only
16	8,1					
18	8,0					Minimum Water Quality
19	8,0	.81				Parameters as set by
20	8,1	.01				pH 7.2
21	8,1			ALCOHOLD THE STATE OF THE STATE		Alk 60 (Alkalinity)
22	8,1					PO4 (Orthophosphate)
23	811					Other ()
24	811					
25	8,0					
26	811					, , , , , , , , , , , , , , , , , , ,
27	811	HELEN MANUAL MAN				Print Name: Son Wanner
28	8,0			MESTANION CHEMICAL CH		Signature: For Warne
29	8,0					Date: /-/- 2023
30	8,0					
31	811					Send to DWP within 10 days after end of sampling period
lo = N	l = Exc	ursion	) Tota	l N's		Samping Police

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/