

## Water Quality Parameter Monitoring Form

## **Lead & Copper Rule Corrosion Control**

Day	рН	Alk	Phos	Other	Y/N	< <have entry="" point<="" th=""></have>
1	7.5					minimum is
2	7,5					been met for this day? PWS ID: 41 9 05 3 1
3	7,5					System Name: Jewell 5D HB
4	7.5					
5	7.4					Entry Point:
6	713	188				Sample Period: 3/2024
7	7,3					Month/Year
8	7,3					Number of excursions* during this month:
9	7,2					(Count the number of days when any WQP was
10	7,4					less than the minimum required)
American American	7.2	¥.				
12	7.4					Total excursions during the previous 5 months:
13	7,3					(Over 9 excursions in 6 months is a violation. Entry
14	7.2					Point and Distribution excursions are cumulative )
15	7.7	178				For OHA use only
16	7.2					
17	7, 2,			1		Minimum Water Quality
18	7.3					Parameters as set by
19	7.2					pH 7, 2
20	7,8					Alk 60 (Alkalinity)
21	7,4					PO4 (Orthophosphate)
22	7,2					Other (
23	7.4					
24	7.4					
25	7,4	-	-			
26	7.4	-	-	-		
27	7,9	-	-			Print Name: Tow Wanner
28	7,4		-			Signature: Warr
29	7.3	176	-			Date: 4/1/2024
30	7,4	-			-	Send to DWP within 10 days after end of
31	7,3					sampling period
(No =	No = N = Excursion) Total N's					

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/