



# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.0				
2	7.9				
3	8.0				
4	—				
5	7.9				
6	—				
7	—				
8	7.8				
9	8.0				
10	7.9				
11	8.0				
12	8.1				
13	—				
14	—				
15	8.1				
16	8.2				
17	8.2				
18	8.1				
19	—				
20	—				
21	—				
22	8.3				
23	8.5				
24	8.5				
25	8.4				
26	—				
27	—				
28	—				
29	9.6				
30	8.4				
31	8.5				

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 90541

System Name: Camas Valley School

Entry Point: Water House

Sample Period: July 2024  
Month/Year

Number of excursions\* during this month: \_\_\_\_\_  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: \_\_\_\_\_  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by**

pH 8

Alk   (Alkalinity)

PO4   (Orthophosphate)

Other   (\_\_\_\_\_)

Print Name: Robert Genke

Signature:

Date: 8/8/24

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's