



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.3				
2	8.2				
3	8.4				
4	—				
5	—				
6	—				
7	8.4				
8	8.1				
9	8.3				
10	8.3				
11	—				
12	—				
13	—				
14	8.4				
15	8.3				
16	8.3				
17	8.4				
18	—				
19	—				
20	—				
21	8.3				
22	8.4				
23	8.3				
24	8.2				
25	—				
26	—				
27	—				
28	8.4				
29	8.3				
30	8.3				
31	8.2				

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 90541

System Name: Camas Valley School

Entry Point: Water House

Sample Period: October 2024
Month/Year

Number of excursions* during this month: _____
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 8.3

Alk (Alkalinity)

PO4 (Orthophosphate)

Other ()

Print Name: Robert Cierke

Signature: *[Signature]*

Date: 11-5-24

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's