



## Water Quality Parameter Monitoring Form

## Lead &amp; Copper Rule Corrosion Control

| Day | pH  | Alk | Phos | Other | Y/N |
|-----|-----|-----|------|-------|-----|
| 1   | 7.8 |     |      |       |     |
| 2   | —   |     |      |       |     |
| 3   | —   |     |      |       |     |
| 4   | —   |     |      |       |     |
| 5   | 7.9 |     |      |       |     |
| 6   | 8.0 |     |      |       |     |
| 7   | 7.8 |     |      |       |     |
| 8   | 7.9 |     |      |       |     |
| 9   | —   |     |      |       |     |
| 10  | —   |     |      |       |     |
| 11  | —   |     |      |       |     |
| 12  | 8.2 |     |      |       |     |
| 13  | 8.3 |     |      |       |     |
| 14  | 8.2 |     |      |       |     |
| 15  | 8.1 |     |      |       |     |
| 16  | —   |     |      |       |     |
| 17  | —   |     |      |       |     |
| 18  | —   |     |      |       |     |
| 19  | 8.1 |     |      |       |     |
| 20  | 8.0 |     |      |       |     |
| 21  | 8.1 |     |      |       |     |
| 22  | 8.0 |     |      |       |     |
| 23  | —   |     |      |       |     |
| 24  | —   |     |      |       |     |
| 25  | —   |     |      |       |     |
| 26  | —   |     |      |       |     |
| 27  | 8.1 |     |      |       |     |
| 28  | 8.0 |     |      |       |     |
| 29  | 8.0 |     |      |       |     |
| 30  | 8.1 |     |      |       |     |
| 31  | —   |     |      |       |     |

(No = N = Excursion) Total N's

<<Have  
minimums  
been met for  
this day?

## ENTRY POINT

PWS ID: 41 90541

System Name: Camas Valley SchoolEntry Point: Water HouseSample Period: May 2025  
Month/Year

Number of excursions\* during this month: \_\_\_\_\_

(Count the number of days when any WQP was  
less than the minimum required)

Total excursions during the previous 5 months: \_\_\_\_\_

(Over 9 excursions in 6 months is a violation. Entry  
Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality  
Parameters as set by

pH

Alk

(Alkalinity)

PO4

(Orthophosphate)

Other

( )

Print Name: Robert GenkeSignature: Robert GenkeDate: June 2, 2025Send to DWP within 10 days after end of  
sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>