



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

| Day | pH | Alk | Phos | Other | Y/N |
|-----|-----|-----|------|-------|-----|
| 1 | — | | | | |
| 2 | — | | | | |
| 3 | 7.9 | | | | |
| 4 | 7.9 | | | | |
| 5 | 7.9 | | | | |
| 6 | 7.9 | | | | |
| 7 | — | | | | |
| 8 | — | | | | |
| 9 | — | | | | |
| 10 | — | | | | |
| 11 | 8.0 | | | | |
| 12 | 7.9 | | | | |
| 13 | — | | | | |
| 14 | — | | | | |
| 15 | — | | | | |
| 16 | — | | | | |
| 17 | — | | | | |
| 18 | 7.9 | | | | |
| 19 | 7.9 | | | | |
| 20 | 7.9 | | | | |
| 21 | — | | | | |
| 22 | — | | | | |
| 23 | — | | | | |
| 24 | 8.0 | | | | |
| 25 | 7.9 | | | | |
| 26 | 8.0 | | | | |
| 27 | 7.9 | | | | |
| 28 | — | | | | |
| 29 | — | | | | |
| 30 | — | | | | |
| 31 | — | | | | |

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 90541

System Name: Camas Valley School

Entry Point: water house

Sample Period: May 2021
Month/Year

Number of excursions* during this month: _____
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 8.0

Alk (Alkalinity)

PO4 (Orthophosphate)

Other (_____)

Print Name: Garrett Moniz

Signature: *Garrett Moniz*

Date: _____

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's