Water Quality Parameter Monitoring Form

# Lead & Copper Rule Corrosion Control

DHS oregon department of human services

| Day | pH | Alk | Phos | Sili | Y/N |
|---|---|---|---|---|---|
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| 7 | 7.5 | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| 14 | 7.6 | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| 21 | 7.5 | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| 29 | 7.5 | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |

(No = N = Excursion) **Total N's** 0

<<Have minimums been met for this day?

County: Lane Agency: REGI

## ENTRY POINT

## EP-A

## PWS ID 4190556

### TRIANGLE LAKE HIGH/ELEM SD 90

**Sample period:** April / 2021
Month/Year

**Number of excursions during this month:** 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

*Reference*

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.2

Print Name: Jeff Richardson

Signature: Jeff Richardson

Date: 04-29-2021

Send to DWP within 10 days after end of sampling period

DHS, Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone: (503) 731-4381 Website: wwww.ohd.hr.state.or.us/dwp