



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
2	7.5				
9	7.4				
16	7.4				
23	7.5				
30	7.5				

<<Have minimums been met for this day?

County: Lane Agency: REGI

ENTRY POINT
EP-A

PWS ID 4190556

TRIANGLE LAKE HIGH/ELEM SD 90

Sample period: June 2021
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

—Reference—

Minimum Water Quality Parameter(s) as set by State:

pH 7.2

Print Name: Jeff Richardson

Signature: [Signature]

Date: 7-6-21

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0