

Water Quality Parameter Monitoring Form
Lead Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7.7				Y
4					
5					
6					
7					
8					
9					
10	7.74				Y
11					
12					
13					
14					
15					
16					
17	7.72				Y
18					
19					
20					
21					
22					
23	7.68				Y
24					
25					
26					
27					
28					
29					
30	7.65				Y
31					
(no = N = Excursion) Total N's					0

<<Have minimums been met for this day?

PWS ID: 41 90556

ENTRY POINT

System Name: Triangle Lake High/Elem SD90
Entry Point: Pump House
Sample Period: Nov 1 2021/Nov 30 2021
 Month/Year

Number of excursions * During this Month: 0
 (Count the number of days when an WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use Only	
Minimum Water Quality Parameters as set by	
pH	7.2
Alk	(Alkalinity)
PO4	(Orthophosphate)
Other	()

Print Name: Shane Benscoter

Signature: 

Date: 12/1/2021

Send to DWP within 10 days after end of sampling period