

Water Quality Parameter Monitoring Form
Lead Copper Rule Corrosion Control

ENTRY POINT

| Day | pH | Alk | Phos | Other | Y/N |
|-----|------|-----|------|-------|-----|
| 1 | | | | | |
| 2 | | | | | |
| 3 | | | | | |
| 4 | | | | | |
| 5 | 7.55 | | | | |
| 6 | | | | | |
| 7 | | | | | |
| 8 | | | | | |
| 9 | | | | | |
| 10 | | | | | |
| 11 | | | | | |
| 12 | 7.32 | | | | |
| 13 | | | | | |
| 14 | | | | | |
| 15 | | | | | |
| 16 | | | | | |
| 17 | | | | | |
| 18 | | | | | |
| 19 | 7.45 | | | | |
| 20 | | | | | |
| 21 | | | | | |
| 22 | | | | | |
| 23 | | | | | |
| 24 | | | | | |
| 25 | | | | | |
| 26 | 7.56 | | | | |
| 27 | | | | | |
| 28 | | | | | |
| 29 | | | | | |
| 30 | | | | | |
| 31 | | | | | |

<<Have minimums
been met for this
day?

PWS ID: 41 90556

System Name: Triangle Lake High/Elem SD90

Entry Point: Pump House

Sample Period: January 1st to January 31st
Month/Year

Number of excursions * During this Month: 0

(Count the number of days when an WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

| | |
|--|------------------|
| For OHA use Only | |
| Minimum Water Quality Parameters as set by | |
| pH | <u>7.2</u> |
| Alk | (Alkalinity) |
| PO4 | (Orthophosphate) |
| Other | () |

Print Name: Shane Benscoter

Signature: 

Date: 2-7-2022

Send to DWP within 10 days after end of sampling period

(no = N = Excursion) Total N's 0