

Water Quality Parameter Monitoring Form  
Lead Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.89				
3					
4					
5					
6					
7					
8					
9	7.65				
10					
11					
12					
13					
14					
15					
16	7.55				
17					
18					
19					
20					
21					
22					
23	7.48				
24					
25					
26					
27					
28					
29					
30					
31					
(no = N = Excursion) Total N's					0

<<Have minimums been met for this day?

PWS ID: 41 90556

### ENTRY POINT

**System Name:** Triangle Lake High/Elem SD90  
**Entry Point:** Pump House  
**Sample Period:** FEBRUARY 1ST TO 28TH  
 Month/Year

**Number of excursions \* During this Month:** 0

(Count the number of days when an WQP was less than the minimum required)

**Total excursions during the previous 5 months:** 0

(over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use Only	
Minimum Water Quality Parameters as set by	
pH	7.2
Alk	(Alkalinity)
PO4	(Orthophosphate)
Other	( )

**Print Name:** Shane Benscoter

**Signature:** 

**Date:** MARCH 8 2022

Send to DWP within 10 days after end of sampling period