

Water Quality Parameter Monitoring Form  
Lead Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.89				Y
2					
3					
4					
5					
6					
7					
8	7.77				Y
9					
10					
11					
12					
13					
14	7.75				Y
15					
16					
17					
18					
19					
20					
21	7.62				Y
22					
23					
24					
25					
26					
27					
28	7.76				Y
29					
30					
31					
(no = N = Excursion) Total N's					0

<<Have minimums been met for this day?

PWS ID: 41 90556

### ENTRY POINT


**System Name:** Triangle Lake High/Elem SD90  
**Entry Point:** Pump House  
**Sample Period:** MARCH 1ST TO 31ST  
Month/Year

**Number of excursions \* During this Month:** 0  
 (Count the number of days when an WQP was less than the minimum required)  
**Total excursions during the previous 5 months:** 0  
 (over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use Only

Minimum Water Quality Parameters as set by

pH	7.2	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		( )

**Print Name:** Shane Benscoter  
**Signature:**   
**Date:** 3/5/2022  
 Send to DWP within 10 days after end of sampling period