

Water Quality Parameter Monitoring Form  
Lead Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.75				Y
2					
3					
4					
5					
6					
7					
8	7.68				Y
9					
10					
11					
12					
13					
14					
15	7.55				Y
16					
17					
18					
19					
20					
21					
22	7.58				Y
23					
24					
25					
26					
27					
28					
29	7.62				
30					
31					
(no = N = Excursion) Total N's					

<<Have minimums been met for this day?

PWS ID: 41 90556

### ENTRY POINT

**System Name:** Triangle Lake High/Elem SD90  
**Entry Point:** Pump House  
**Sample Period:** JUNE 1ST TO JUNE 30TH 2022  
Month/Year

**Number of excursions \* During this Month:** 0

(Count the number of days when an WQP was less than the minimum required)

**Total excursions during the previous 5 months:** 0

(over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use Only

Minimum Water Quality Parameters as set by

pH	7.2	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		( )

**Print Name:** Shane Benscoter

**Signature:** 

**Date:** 7-6-2022

Send to DWP within 10 days after end of sampling period