

Water Quality Parameter Monitoring Form  
Lead Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.62				Y
2					
3					
4					
5					
6					
7					
8	7.71				Y
9					
10					
11					
12					
13					
14					
15	7.78				Y
16					
17					
18					
19					
20					
21					
22	7.76				Y
23					
24					
25					
26					
27					
28					
29	7.68				Y
30					
31					
(no = N = Excursion) Total N's					0

<<Have minimums  
been met for this  
day?

PWS ID: 41 90556

**ENTRY POINT**

**System Name:** Triangle Lake High/Elem SD90  
**Entry Point:** Pump House  
**Sample Period:** March 1st to March 31st 2023  
 Month/Year

**Number of excursions \* During this Month:** 0

(Count the number of days when an WQP was less than the minimum required)

**Total excursions during the previous 5 months:** 0  
 (over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use Only	
Minimum Water Quality Parameters as set by	
pH	<u>7.2</u>
Alk	(Alkalinity)
PO4	(Orthophosphate)
Other	( )

**Print Name:** Shane Bencoter

**Signature:** 

**Date:** 4/3/2023

Send to DWP within 10 days after end of sampling period