



**Water Quality Parameter Monitorin Form
Lead Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7.79				
4					
5					
6					
7					
8					
9					
10	7.75				
11					
12					
13					
14					
15					
16					
17	7.66				
18					
19					
20					
21					
22					
23					
24	7.73				
25					
26					
27					
28					
29					
30					
31	7.78				
(no = N = Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 90556

System Name: Triangle Lake High/Elem SD90
Entry Point: Pump House
Sample Period: May 1st 2023 to May 31st 2023
 Month/Year

Number of excursions * During this Month: 0

(Count the number of days when an WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use Only	
Minimum Water Quality Parameters as set by	
pH	7.2
Alk	(Alkalinity)
PO4	(Orthophosphate)
Other	()

Print Name: Shane Benscoter

Signature: 

Date: June 5th 2023

Send to DWP within 10 days after end of sampling period