

Water Quality Parameter Monitorin Form
Lead Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7.6				Y
4					
5					
6					
7					
8					
9					
10	7.5				Y
11					
12					
13					
14					
15					
16					
17	7.5				Y
18					
19					
20					
21					
22					
23					
24	7.4				Y
25					
26					
27					
28					
29					
30					
31					
(no = N = Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 90556

System Name: Triangle Lake High/Elem SD90
Entry Point: Pump House
Sample Period: 04/01/2024-04/30/2024
Month/Year

Number of excursions * During this Month: 0

(Count the number of days when an WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use Only

Minimum Water Quality Parameters as set by

pH	7.2	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		()

Print Name: Shane Benscoter

Signature:

Date: 5/6/2024

Send to DWP within 10 days after end of sampling period