



Water Quality Parameter Monitorin Form
Lead Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.4				Y
2					
3					
4					
5					
6					
7					
8	7.5				Y
9					
10					
11					
12					
13					
14					
15	7.5				Y
16					
17					
18					
19					
20					
21					
22	7.6				Y
23					
24					
25					
26					
27					
28					
29	7.5				Y
30					
31					
(no = N = Excursion) Total N's					0

<<Have minimums been met for this day?

PWS ID: 41 90556

ENTRY POINT

System Name: Triangle Lake High/Elem SD90
Entry Point: Pump House
Sample Period: 05/01/2024-05/31/2024
 Month/Year

Number of excursions * During this Month: 0
 (Count the number of days when an WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use Only	
Minimum Water Quality Parameters as set by	
pH	<u>7.2</u>
Alk	(Alkalinity)
PO4	(Orthophosphate)
Other	()

Print Name: Shane Benscoter

Signature:

Date: 6/3/2024

Send to DWP within 10 days after end of sampling period