

**Water Quality Parameter Monitorin Form**  
**Lead Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6					
7	7.6				Y
8					
9					
10					
11					
12					
13					
14	7.5				Y
15					
16					
17					
18					
19					
20					
21	7.4				Y
22					
23					
24					
25					
26					
27					
28	7.5				Y
29					
30					
31					
(no = N = Excursion) Total N's					0

<<Have minimums been met for this day?

PWS ID: 41 90556

**ENTRY POINT**

**System Name:** Triangle Lake High/Elem SD90  
**Entry Point:** Pump House  
**Sample Period:** 08/01/2024-08/31/2024  
 Month/Year

**Number of excursions \* During this Month:** 0

(Count the number of days when an WQP was less than the minimum required)

**Total excursions during the previous 5 months:** 0  
 (over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use Only	
Minimum Water Quality Parameters as set by	
pH	<u>7.2</u>
Alk	(Alkalinity)
PO4	(Orthophosphate)
Other	( )

**Print Name:** Shane Benscoter

**Signature:**

**Date:** 9/3/2024

Send to DWP within 10 days after end of sampling period