

Water Quality Parameter Monitorin Form

Lead Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6					
7	7.3				Y
8					
9					
10					
11					
12					
13					
14	7.5				Y
15					
16					
17					
18					
19					
20					
21	7.5				Y
22					
23					
24					
25					
26					
27					
28	7.7				Y
29					
30					
31					
(no = N = Excursion) Total N's					0

<<Have minimums
been met for this
day?

PWS ID: 41 90556

ENTRY POINT

System Name: Triangle Lake High/Elem SD90
Entry Point: Pump House
Sample Period: 5/1/2025-5/31/2025
 Month/Year

Number of excursions * During this Month: 0

(Count the number of days when an WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use Only

Minimum Water Quality
Parameters as set by

pH	7.2	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		()

Print Name: Shane Benscoter

Signature: 

Date: 6/2/2025

Send to DWP within 10 days after end of sampling period