

Water Quality Parameter Monitorin Form Lead Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4	7.5				
5					
6					
7					
8					
9					
10					
11	7.7				
12					
13					
14					
15					
16					
17					
18	7.7				
19					
20					
21					
22					
23					
24					
25	7.4				
26					
27					
28					
29					
30					
31					
(no = N = Excursion) Total N's					0

<<Have minimums
been met for this
day?

PWS ID: 41 90556

ENTRY POINT

System Name: Triangle Lake High/Elem SD90
Entry Point: Pump House
Sample Period: 6/1/2025-6/30/2025
 Month/Year

Number of excursions * During this Month: 0

(Count the number of days when an WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use Only

Minimum Water Quality
Parameters as set by

pH	7.2	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		()

Print Name: Shane Benscoter

Signature:

Date: 7/1/2025

Send to DWP within 10 days after end of
sampling period