

## Water Quality Parameter Monitorin Form Lead Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.6				Y
3					
4					
5					
6					
7					
8					
9	7.6				Y
10					
11					
12					
13					
14					
15					
16	7.4				Y
17					
18					
19					
20					
21					
22					
23	7.5				Y
24					
25					
26					
27					
28					
29					
30					
31	7.7				Y
(no = N = Excursion) Total N's					0

<<Have minimums  
been met for this  
day?

PWS ID: 41 90556


### ENTRY POINT

System Name: Triangle Lake High/Elem SD90  
Entry Point: Pump House  
Sample Period: 7/1/2025-7/31/2025  
Month/Year

Number of excursions \* During this Month: 0  
(Count the number of days when an WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
(over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use Only	
Minimum Water Quality Parameters as set by	
pH	7.2
Alk	(Alkalinity)
PO4	(Orthophosphate)
Other	( )

Print Name: Shane Benscoter  
Signature:   
Date: 8/4/2025

Send to DWP within 10 days after end of sampling period