

# Water Quality Parameter Monitorin Form

## Lead Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6	7.8				Y
7					
8					
9					
10					
11					
12					
13	7.5				Y
14					
15					
16					
17					
18					
19					
20	7.5				Y
21					
22					
23					
24					
25					
26					
27	7.7				Y
28					
29					
30					
31					
(no = N = Excursion) Total N's					0

<<Have minimums  
been met for this  
day?

PWS ID: 41 90556

### ENTRY POINT

**System Name:** Triangle Lake High/Elem SD90  
**Entry Point:** Pump House  
**Sample Period:** 8/1/2025-8/31/2025  
 Month/Year

**Number of excursions \* During this Month:** 0

(Count the number of days when an WQP was less than the minimum required)

**Total excursions during the previous 5 months:** 0  
 (over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use Only

Minimum Water Quality  
Parameters as set by

pH	7.2	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		( )

**Print Name:** Shane Benscoter

**Signature:** 

**Date:** 9/4/2025

Send to DWP within 10 days after end of sampling period