

Water Quality Parameter Monitoring Form
Lead Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.5				Y
2					
3					
4					
5					
6					
7					
8	7.7				Y
9					
10					
11					
12					
13					
14					
15	7.7				Y
16					
17					
18					
19					
20					
21					
22	7.6				Y
23					
24					
25					
26					
27					
28					
29	7.5				Y
30					
31					
(no = N = Excursion) Total N's					0

<<Have minimums
been met for this
day?

PWS ID: 41 90556

ENTRY POINT

System Name: Triangle Lake High/Elem SD90

Entry Point: Pump House

Sample Period: 10/1/2025-10/31/2025

Month/Year

Number of excursions * During this Month: 0

(Count the number of days when an WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use Only

Minimum Water Quality
Parameters as set by

pH	7.2
Alk	(Alkalinity)
PO4	(Orthophosphate)
Other	()

Print Name: Shane Benscoter

Signature:



Date: 11/3/2025

Send to DWP within 10 days after end of
sampling period

OHS Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971)673-0405 Website: <http://healthoregon.org/dwp/>