

Water Quality Parameter Monitoring Form
Lead Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5	7.5				Y
6					
7					
8					
9					
10					
11					
12	7.6				Y
13					
14					
15					
16					
17					
18					
19	7.5				Y
20					
21					
22					
23					
24					
25					
26	7.7				Y
27					
28					
29					
30					
31					
(no = N = Excursion) Total N's				0	

<<Have minimums
been met for this
day?

ENTRY POINT

PWS ID: 41 90556

System Name: Triangle Lake High/Elem SD90

Entry Point: Pump House

Sample Period: Nov 1-Nov 30 2025

Month/Year

Number of excursions * During this Month: 0

(Count the number of days when an WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use Only

Minimum Water Quality
Parameters as set by

pH	7.2
Alk	(Alkalinity)
PO4	(Orthophosphate)
Other	()

Print Name: Shane Benscoter

Signature:



Date: 12/1/2025

Send to DWP within 10 days after end of
sampling period

OHS Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971)673-0405 Website: <http://healthoregon.org/dwp/>