

Water Quality Parameter Monitorin Form  
**Lead Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7.8				Y
4					
5					
6					
7					
8					
9					
10	7.6				Y
11					
12					
13					
14					
15					
16					
17	7.5				Y
18					
19					
20					
21					
22					
23	7.4				Y
24					
25					
26					
27					
28					
29					
30	7.6				Y
31					
(no = N = Excursion) Total N's					0

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 90556

**System Name:** Triangle Lake High/Elem SD90  
**Entry Point:** Pump House  
**Sample Period:** 12-1-2025/12-31-2025  
 Month/Year

**Number of excursions \* During this Month:** 0  
 (Count the number of days when an WQP was less than the minimum required)

**Total excursions during the previous 5 months:** 0  
 (over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use Only	
Minimum Water Quality Parameters as set by	
pH	<u>7.2</u>
Alk	(Alkalinity)
PO4	(Orthophosphate)
Other	( )

**Print Name:** Shane Benscoter  
**Signature:**   
**Date:** 1/6/2025

Send to DWP within 10 days after end of sampling period