

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6					
7	8.57				
8					
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19	7.95				
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Marion Agency: MARION COUNTY

ENTRY POINT

EP-A

PWS ID 4190587

SILVER CREST SCHOOL

Sample period: July 2021
 Month/Year

Number of excursions during this month: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.2

Print Name: HELEN FEJEN

Signature: [Handwritten Signature]

Date & Phone#: 7/7/21

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's