

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6					
7					
8					
9	8.19				
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24	8.16				
25					
26					
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Marion Agency: MARION COUNTY

**ENTRY POINT**  
**EP-A**

**PWS ID 4190587**  
**SILVER CREST SCHOOL**

Sample period: 9 / 2021  
Month/Year

Number of excursions during this month: \_\_\_\_\_

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

Minimum Water Quality Parameter(s) as set by State:

pH

Print Name: Lorin Stanley  
Signature: [Signature]  
Date & Phone#: 9-9-21 503 991-6572

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's