

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14	7.66				
15					
16					
17					
18					
19					
20					
21					
22	7.94				
23					
24					
25					
26					
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Marion Agency: MARION COUNTY

ENTRY POINT
EP-A

PWS ID 4190587
SILVER CREST SCHOOL

Sample period: DECEMBER 2021
Month/Year

Number of excursions during this month: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.2

Print Name: HELEN FUSTON
Signature: Helen Fuston
Date & Phone: 12/14/21

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's