



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.73	166			
2					
3					
4					
5					
6					
7					
8					
9	8.88	176			
10					
11					
12					
13					
14	9.10	173			
15					
16					
17					
18					
19					
20					
21					
22					
23	8.5	167			
24					
25					
26					
27					
28	8.47	178			
29					
30					
31					

<<Have minimums been met for this day?

County: Marion Agency: MARION COUNTY

ENTRY POINT

EP-A

PWS ID 4190587

SILVER CREST SCHOOL

Sample period: February 2022
Month/Year

Number of excursions during this month: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.2

Print Name: Dustin Hoelme

Signature: _____

Date & Phone#: 2/1/22

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's