

Day	pH	Alk	Phos	Other	Y/N
1					
* 2	10.16	144			
3					
4					
5					
6					
7					
+ 8	10.24	154			
9					
10					
11					
12					
13					
14					
15					
16					
17					
+ 18	8.80	143			
19					
20					
21					
+ 22	8.77	134			
23					
24					
25					
26					
27					
28					
+ 29	8.25	149			
30					
31					

<<Have minimums been met for this day?

County: Marion Agency: MARION COUNTY

ENTRY POINT

EP-A

PWS ID 4190587

SILVER CREST SCHOOL

Sample period: January 2024
 Month/Year

Number of excursions during this month: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference _____

Minimum Water Quality Parameter(s) as set by State:

pH 7.2

Print Name: Dustin Hoehn

Signature: [Signature]

Date & Phone#: [Signature] 503-873-5303

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's**