

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
* 5	8.24	149			
6					
7					
8					
9					
10					
11					
* 12	8.0	147			
13					
14					
15					
16					
17					
18					
19					
* 20	7.58	136			
21					
22					
23					
24					
25					
* 26	8.41	141			
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Marion Agency: MARION COUNTY

ENTRY POINT

EP-A

PWS ID 4190587

SILVER CREST SCHOOL

Sample period: February 2024
 Month/Year

Number of excursions during this month: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.2

Print Name: Dustin Hoehn

Signature: [Signature]

Date & Phone#: 503-873-5303

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's**