

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6	8.69	135			
7					
8					
9					
10					
11					
12					
13	8.34	129			
14					
15					
16					
17					
18					
19					
20	9.23	134			
21					
22					
23					
24					
25					
26					
27					
28					
29	8.30	120			
30					
31					

<<Have minimums been met for this day?

County: Marion Agency: MARION COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4190587**

**SILVER CREST SCHOOL**

Sample period: May 2024  
 Month/Year

Number of excursions during this month: \_\_\_\_\_

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.2

Print Name: Dustin Hoedre

Signature: \_\_\_\_\_

Date & Phone#: 5/6/24

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's**