

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
* 6	8.17	137			
7					
8					
9					
10					
11					
* 12	8.27	135			
13					
14					
15					
16					
17	9.33	128			
18					
19					
20					
21					
22					
23					
24					
* 25	7.82	110			
26					
27					
28					
29					
30					
31					

(No = N = Excursion) **Total N's**

<<Have
minimums
been met for
this day?

County: Marion Agency: MARION COUNTY

ENTRY POINT

EP-A

PWS ID 4190587

SILVER CREST SCHOOL

Sample period: September 2024
Month/Year

Number of excursions during this month: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference _____

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.2

Print Name: Jeff Alderman

Signature: [Signature]

Date & Phone#: 9/6/24 503-991-6572

Send to DWP within 10 days after end of
sampling period