

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	8.82	128			Y
4					
5					
6					
7					
8					
9					
10					
* 11	9.21	123			
12					
13					
14					
15					
16					
17					
* 18	8.04	132			
19					
20					
21					
22					
23					
* 24	8.47	129			
25					
26					
27					
28					
29					
* 30	8.35	126			
31					

(No = N = Excursion) Total N's

<<Have
minimums
been met for
this day?

County: Marion Agency: MARION COUNTY

ENTRY POINT

EP-A

PWS ID 4190587

SILVER CREST SCHOOL

Sample period: October 2024
Month/Year

Number of excursions during this month:

(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.2

Print Name: Jeff Anderson

Signature: [Signature]

Date & Phone#:

Send to DWP within 10 days after end of
sampling period