

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6					
7					
X 8	7.76	116			
9					
10					
11					
12					
13					
14					
* 15	7.57	112			
16					
17					
18					
19					
20					
21					
* 22	7.61	107			
23					
24					
25					
26					
* 27	7.38	95			
28					
29					
30					
31					

(No = N = Excursion) Total N's   

<<Have  
minimums  
been met for  
this day?

County: Marion Agency: MARION COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4190587**

**SILVER CREST SCHOOL**

Sample period: November 2024  
Month/Year

Number of excursions during this month:       

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

**Minimum Water Quality  
Parameter(s) as set by State:**

pH 7.2

Print Name: Jeff Aderman

Signature: [Signature]

Date & Phone#: 11/8/2024 503-991

Send to DWP within 10 days after end of sampling period 6572