

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6	7.96	158			
7					
8					
9					
10					
11					
12					
13	8.32	108			
14					
15					
16					
17					
18	8.20	172			
19					
20					
21					
22					
23					
24	8.09	154			
25					
26					
27					
28					
29					
30					
31					

(No = N = Excursion) **Total N's**   

<<Have  
minimums  
been met for  
this day?

County: Marion Agency: MARION COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4190587**

**SILVER CREST SCHOOL**

Sample period: June 2025  
Month/Year

Number of excursions during this month:       

(Over 9 excursions in 6 months is a violation.  
Entry Point and Distribution excursions are  
cumulative). An 'excursion' is any day in which the  
water quality parameter(s) fall below the minimum  
set by the State.

Reference

**Minimum Water Quality  
Parameter(s) as set by State:**

pH 7.2

Print Name: Jeff Alderman

Signature: [Signature]

Date & Phone#: 7-1-25 503-991-6572

Send to DWP within 10 days after end of  
sampling period