

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6	7.21	127			
7					
8					
9					
10					
11					
12					
13					
14	7.64	156			
15					
16					
17					
18					
19					
20					
21	7.52	142			
22					
23					
24					
25	7.47	149			
26					
27					
28					
29					
30					
31					

(No = N = Excursion) **Total N's**

<<Have
minimums
been met for
this day?

County: Marion Agency: MARION COUNTY

ENTRY POINT

EP-A

PWS ID 4190587

SILVER CREST SCHOOL

Sample period: NOVEMBER 2025
Month/Year

Number of excursions during this month: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH	7.2
Alk	120.0 (Alkalinity)

Print Name: Jeff Alderman

Signature: Jeff Alderman

Date & Phone#: 503-991-6572 12.8.25

Send to DWP within 10 days after end of
sampling period