

Day	pH	Alk	Phos	Other	Y/N
1					
* 2	7.74	149			
3					
4					
5					
6					
7					
8					
* 9	7.87	151			
10					
11					
12					
13					
14					
15					
16					
* 17	7.93	160			
18					
19					
20					
21					
22					
23					
24					
25					
26					
* 27	8.08	174			
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Marion Agency: MARION COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4190587**

**SILVER CREST SCHOOL**

Sample period: MARCH 2026  
Month/Year

Number of excursions during this month: \_\_\_\_\_

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 

7.2
-----

  
Alk 

120.0
-------

 (Alkalinity)

Print Name: Jeff Aideman

Signature: [Signature]

Date & Phone#: 3-27-26 503-991-6572

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 

--