

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	рН	Alk	Phos		Y/N
1				TOMP.	
2 3 4					
3					
5					
6					
7	7.8			14.8c	N
8					
9					
10					
11					
12					
13	7.7			14.50	N
14					
15					
16					
17					
18					
19					
20	1.8			14.2	N
21					
22					
23					
24					
25					
26					
27	7.8			14.4	N
28					
29					
30					
31					
1= 0	V = Ex	cursio	n) Tot a	ıl N's	0

< <have minimums</have 	County: Lane Agency: LANE COUNTY ENTRY POINT
been met for this day?	EP-A
	PWS ID 4190894
AP	PLEGATE ELEMENTARY 66
Sample no	eriod: Feb. 2025
Sample p	Month/Year

Number of excursions during this month: ____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

	num Water Quality neter(s) as set by State:
рН	7.6

Print Name: 15 year 2000 Date & Phone#: 541 510 5986 3/6/25

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/