

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1				Temp	
2					
3	7.8			14.8	N
4					
5					
6					
7					
8					
9					
10	7.7			14.8	N
11					
12					
13					
14					
15					
16					
17	7.7			15	N
18					
19					
20					
21					
22					
23					
24	7.6			14.9	N
25					
26					
27					
28					
29					
30					
31					

(No = N = Excursion) **Total N's** 0

<<Have
minimums
been met for
this day?

County: Lane

Agency: LANE COUNTY

ENTRY POINT

EP-A

PWS ID 4190894

APPLEGATE ELEMENTARY 66

Sample period: April 2025
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).
An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.6

Print Name: Bryan Wood

Signature: Bryan Wood

Date & Phone#: 5/6/25 541 510 5986

Send to DWP within 10 days after end of
sampling period