

### Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5	7.6			14.8	
6					
7					
8					
9					
10					
11					
12	7.6			14.9	
13					
14					
15					
16					
17					
18					
19	7.7			14.6	
20					
21					
22					
23					
24					
25					
26	7.7			14.7	
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Lane

Agency: LANE COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4190894**

**APPLEGATE ELEMENTARY 66**

Sample period: June 1 2025  
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.6

Print Name: Bryan Wood  
Signature: Bryan Wood  
Date & Phone#: July 3 541 510 5981

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** N

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>