

## Water Quality Parameter Monitoring Form

## **Lead & Copper Rule Corrosion Control**

Day	рН	Alk	Phos	Other	Y/N
1					
2					
2					
4					
5	7.7			15.90	
6					
7					
8					
9					
10					
11	7,7			15.9	7
12					
13					
14					
15					
16					
17					
18	7.7			16.0	4
19					
20					
21					
22					
23					
24					
25	7.6			15,9	4
26					
27					
28					
29					
30					
31					
10 = 1	۷ = Ex	cursio	n) Tota	al N's	0

< <have< th=""><th>County: Lane Agency: LANE COUNTY</th><th></th></have<>	County: Lane Agency: LANE COUNTY				
minimums	<b>ENTRY POINT</b>				
been met for this day?	EP-A				
	PWS ID 4190894				
AP	PLEGATE ELEMENTARY 66				
Sample p	eriod: Sept 2025				
	Month/Year				

Number of excursions during this month:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

-Reference
Minimum Water Quality Parameter(s) as set by State:
pH 7.6
2
Print Name: Dryan Wood
Signature: Bryan Wood
Date & Phone#: Uoct 2 2025
Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/