

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6					
7					
8	7.8			14.6	Ø
9					
10					
11					
12					
13					
14					
15	7.7			14.8	Ø
16					
17					
18					
19					
20					
21	7.7			14.4	Ø
22					
23					
24					
25					
26					
27					
28					
29					
30	7.7			14.4	Ø
31					

<<Have minimums been met for this day?

County: Lane Agency: LANE COUNTY

ENTRY POINT

EP-A

PWS ID 4190894

APPLEGATE ELEMENTARY 66

Sample period: JAN 2026
 Month/Year

Number of excursions during this month: Ø

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference _____

Minimum Water Quality Parameter(s) as set by State:

pH 7.6

Print Name: Bryan Wood
 Signature: Bryan Wood
 Date & Phone#: 2/4/26

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** Ø