

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5	7.6			14C	
6					
7					
8					
9					
10					
11					
12					
13	7.8			14C	
14					
15					
16					
17					
18					
19	7.7			14.2C	
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31	7.7			14.3C	

<<Have minimums been met for this day?

County: Lane Agency: LANE COUNTY

ENTRY POINT

EP-A

PWS ID 4190894

APPLEGATE ELEMENTARY 66

Sample period: MARCH 2026
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

-Reference-

Minimum Water Quality Parameter(s) as set by State:

pH 7.6

Print Name: Bryan Wood
Signature: Bryan Wood
Date & Phone#: 5-1-26 541 510 5986

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0