

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.70	160	1.02	/	Y
2					
3					
4					
5					
6					
7					
8	7.61	160	1.08		Y
9					
10					
11					
12					
13					
14					
15	7.54	160	0.99		Y
16					
17					
18					
19					
20					
21					
22	7.46	150	0.92		Y
23					
24					
25					
26					
27					
28	7.70	160	0.92		Y
29					
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 9 1 1 6 7

System Name: Mt. Hood Meadows Spring

Entry Point: A

Sample Period: January - 2021
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2
Alk 99 (Alkalinity)
PO4 0.8 (Orthophosphate)
Other / ()

Print Name: Patricio Ramos Pino

Signature: [Signature]

Date: 2-10-2021

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0