



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.65	140	0.95		Y
3					
4					
5					
6					
7					
8	7.58	140	0.92		Y
9					
10					
11					
12					
13	7.75	160	0.99		Y
14					
15					
16					
17					
18					
19	7.88	160	0.95		Y
20					
21					
22	7.73	140	0.92		Y
23					
24					
25					
26					
27					
28					
29	7.38	140	0.92		Y
30					
31					

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 91167

System Name: Mt. Hood Meadows Spring

Entry Point: A

Sample Period: April - 2022
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.2	
Alk	99	(Alkalinity)
PO4	0.8	(Orthophosphate)
Other	/	()

Print Name: Patricio Ramos Pineda

Signature: *Patricio Ramos Pineda*

Date: 08-05-22

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0