

Day	pH	Alk	Phos	Other	Y/N
1				/	
2					
3					
4					
5					
6	7.63	160	1.28		Y
7					
8					
9					
10					
11	7.70	160	1.35		Y
12					
13					
14					
15					
16					
17					
18	7.64	160	0.99		Y
19					
20					
21					
22					
23					
24					
25	7.80	160	0.92		Y
26					
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 91167

System Name: Mt. Hood Meadows Spring

Entry Point: A

Sample Period: July - 2022
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.2	
Alk	99	(Alkalinity)
PO4	0.8	(Orthophosphate)
Other	/	(_____)

Print Name: Patricia Ramos Pino

Signature: *Patricia Ramos Pino*

Date: 8/08/22

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0