

Day	pH	Alk	Phos	Other	Y/N
1	7.83	160	0.95	/	Y
2					
3					
4					
5					
6					
7					
8	7.63	160	0.92		Y
9					
10					
11					
12					
13					
14					
15	7.67	160	0.95		Y
16					
17					
18					
19					
20					
21					
22					
23					
24					
25	7.63	160	0.92		Y
26					
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 91167

System Name: Mt. Hood Meadows Spring

Entry Point: A

Sample Period: August - 2022
Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.2	
Alk	99	(Alkalinity)
PO4	0.8	(Orthophosphate)
Other	/	()

Print Name: Patricio Ramos Pino

Signature: *Patricio Ramos Pino*

Date: 09-08-22

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0