

Day	pH	Alk	Phos	Other	Y/N
1				/	
2					
3	7.50	140	1.15		Y
4					
5					
6					
7					
8					
9					
10					
11	7.42	140	1.08		Y
12					
13					
14					
15					
16					
17					
18	7.38	140	1.08		Y
19					
20					
21					
22					
23					
24					
25					
26	7.38	140	1.15		Y
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 91167

System Name: Mt. Hood Meadows Spring

Entry Point: A

Sample Period: October - 2022  
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH	<span style="border: 1px solid black; padding: 2px;">7.2</span>	
Alk	<span style="border: 1px solid black; padding: 2px;">99</span>	(Alkalinity)
PO4	<span style="border: 1px solid black; padding: 2px;">0.8</span>	(Orthophosphate)
Other	<span style="border: 1px solid black; padding: 2px;">/</span>	( )

Print Name: Patricio Ramos Pino  
Signature: *Patricio Ramos Pino*  
Date: 11-06-22

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0