

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.60	160	1.15		Y
3					
4					
5					
6					
7					
8					
9					
10	7.45	140	0.92		Y
11					
12					
13					
14					
15					
16	7.54	160	0.99		Y
17					
18					
19					
20					
21					
22					
23					
24					
25	7.57	160	0.95		Y
26					
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 91167

System Name: Mt. Hood Meadows Spring

Entry Point: A

Sample Period: February - 2023
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<u>7.2</u>	
Alk	<u>99</u>	(Alkalinity)
PO4	<u>0.8</u>	(Orthophosphate)
Other	<u>/</u>	()

Print Name: Patricio Ramos Pino

Signature: [Signature]

Date: 3-09-2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0